

**KS-5312 EMERGENCY CELL SWITCH, AND
AUTOMATIC SWITCH COMPANY TRANSFER SWITCHES
HAVING NO KS DESIGNATIONS
REQUIREMENTS AND ADJUSTING PROCEDURES**

1. GENERAL

1.001 This addendum supplements Section 030-790-701, Issue 1.

1.002 This addendum is issued to specify the use of KS-19578 L1 trichloroethane wherever KS-8372 trichloroethylene is now specified. The same precautions that apply for KS-8372 trichloroethylene shall apply to the KS-19578 L1 trichloroethane.